



HRS Roofing Solutions (Pty) Ltd

SARS VAT Reg. No: 4330281256

Registered Asbestos Contractor #

OHH/RAC2019/CI-128

Postal Address: Po Box 53272, Kenilworth, 7745

Online Office: Jupiter Road, Athlone, 7764

Tel: 081 323 1112

Tel: 021 633 0214 (after hours)

E-mail: sales@hrsroofing.co.za

www.hrsroofing.co.za


**EXAMPLE OF AN ASBESTOS SAMPLE
TEST REPORT**

Dear Client

With reference to the bulk sample analyzed for asbestos content, and taken from
.....we hereby submit the following report:

Ref: 2020 AJ23
Date of report: 04 February 2020
Client: HRS Roofing Solutions
Sample taken from: CAPE TOWN
Analysed by:
Date Analyzed: 4th February 2020
Instruction: Analyze sample for asbestos content.
Evaluation strategy: HSG 248. The analysts' guide for sampling, analysis and clearance procedures.
Equipment used: Zeiss Axio Microscope fitted with Polarization mode enhancement for asbestos content determination.

2. RESULTS:

Sample No:	Sample Date	Date of sample analysis	Sample Description	Comments	Standard
2020-041-BS1	28.01.2020	04.02.2020	Bulk Sample: Rooftile. 	Positive for asbestos content. The type of asbestos identified is Chrysotile.	HSG 248.

The bulk sample 2020-041-BS1 analyzed on the 4th of February 2020 is **positive for asbestos content**. The type of asbestos identified is Chrysotile.

The sample analysis was carried out in accordance with bulk sample analysis standard HSG 248, the analysts' guide for sampling, analysis and clearance procedures.